



ItemNo	Category	Voltage	Cycle	Phase	Amps	Hp	ConnectionType	Rough-In AFF	Quantity	Electrical Remarks
2	POS Terminals	220	50	1	tbd		J-Box	Floor	3	By Owner, Confirm Electrical
3	Soda Ice & Beverage Dispenser	220	50	1	tbd		J-Box	Floor	1	By Owner, Confirm Electrical
11	Rear Serving Counter	120/208	50-60	1	Verify		J-Box	Floor	1	Main Incoming for Elec Panel
11.2	Hot Food Wait Unit, Drop-In, Electric	208-240	50-60	1	3.0		J-Box	n/a	2	Elec. Supply from #11 Elec. Panel
11.3	Hot Food Wait Unit, Drop-In, Electric	208/240	50-60	3	15.8		J-Box	n/a	1	Elec. Supply from #11 Elec. Panel
12	French Fry Warmer	230	50	1	5.9		Floor	n/a	1	Elec. Supply from #11 Elec. Panel
13	Refrigerated Merchandiser	230-240	50	1	2.4	1/3	Simplex	n/a	1	Elec. Supply from #11 Elec. Panel
14	Display Case, Hot Food, Countertop	120	50-60	1	12.0		Simplex	n/a	1	Elec. Supply from #11 Elec. Panel
21	Sandwich / Salad Preparation Refrigerator	230-240	50	1	6.5	1/3	Simplex	18"	1	By Owner, Confirm Electrical
22	Microwave Oven	230-240	50	1	13		Simplex	72"	1	By Owner, Confirm Electrical
23	Mobile Heated Cabinet	230	50-60	1	7.7		Special	18"	1	By Owner, Confirm Electrical
27	Undercounter Refrigerator	230	50-60	1	3.5	1/5	Simplex	Floor	1	Stub up from Floor
28	Reach-In Undercounter Freezer	230	50-60	1	2.1	1/2	Simplex	Floor	1	Stub up from Floor
29	Warming Drawer, Built-In	208-240	50-60	1	3.3-3.8		J-Box	Floor	1	Stub up from Floor
31	Gas Floor Fryer	230	50	1	6.2		J-Box	18"	3	
32	Fryer Dump Station	230	50-60	1	3.0		Simplex	18"	1	By Owner, Confirm Electrical
34	Kettle, Gas, Tilting	230	50	1	1.0		J-Box	18"	1	
36	Combi Oven, Electric	220	50/60	1	28.0		J-Box	18"	1	Confirm Elec with Ownership
37	Rice / Grain Cooker	240	60	1	10.4		Simplex	48"	2	
38	Main Hood	115	50-60	1	tbd		J-Box	108"	1	Elec for Lights in Hood By Owner, Confirm Electrical
38.1	Exhaust Fan	208	50	3	tbd		J-Box	108"	1	By Owner, Confirm Electrical
38.2	Supply Fan	208	50	3	tbd		J-Box	108"	1	By Owner, Confirm Electrical
41	Work Table, Stainless Steel Top	115/230	50	1	15		Duplex	48"	1	Convenience Outlet, Confirm Elec w/ Owner
42	Undercounter Refrigerator	230-240	50	1	1.8	1/6	Simplex	18"	1	
52	Ice Cuber	220-240	50	1	6.8		J-Box	72"	1	By Owner, Confirm Electrical
61	Walk-In Combo	115	50	1	15		J-Box	ceiling	1	By Owner, Confirm Electrical
61.1	Evaporator	220	50	1	10		J-Box	ceiling	1	By Owner, Confirm Electrical
61.2	Condensing Unit	220	50	1	32		J-Box	18"	1	By Owner, Confirm Electrical
61.3	Evaporator	220	50	1	10		J-Box	ceiling	1	By Owner, Confirm Electrical
61.4	Condensing Unit	220	50	1	32		J-Box	18"	1	By Owner, Confirm Electrical



Exhaust & Supply Fans to be located by Architect on Roof Not To Scale

To be located by Architect on Roof Not To Scale

- LEGEND - ELECTRICAL CONNECTIONS**
- DUPLEX RECEPT., 15-AMP, 120-VOLT, GROUND TYPE, HORIZONTAL MOUNT
  - SIMPLEX RECEPT., 120-VOLT, GROUND TYPE, HORIZONTAL MOUNT
  - SPECIAL PURPOSE OUTLET, GROUND TYPE, HORIZONTAL MOUNT
  - JUNCTION BOX, DIRECT CONNECTION
  - DISCONNECT SWITCH, DIRECT CONNECTION
  - FLOOR/CEILING RECEPTACLE AS INDICATED
  - (2) Telephone + (2) Data
  - FIELD CONNECTIONS
  - HARD WIRE CONNECTION POINT AT MACHINE



NOTE # E2  
ALL NATIONAL, STATE, AND LOCAL CODES SHALL APPLY

NOTE # E3  
ALL ELECTRICAL CONNECTIONS AND HARDWARE REQUIRED TO BE PROVIDED BY ELECTRICAL CONTRACTOR

NOTE # E4  
ALL JUNCTION BOXES, OUTLETS, ETC. TO BE LOCATED SO AS TO NOT INTERFERE WITH EQUIPMENT

NOTE # E5  
ALL RELAYS, CONTRACTORS, STARTERS, AND SWITCHES REQUIRED FOR EXHAUST & SUPPLY FANS TO BE PROVIDED BY ELECTRICAL CONTRACTOR UNLESS SPECIFIED

NOTE # E6  
ELECTRICAL CONTRACTOR TO INTERCONNECT DISHMACHINE TO EXHAUST FAN FOR DISHMACHINE SO THAT THE FAN RUNS WHEN THE DISHMACHINE IS IN OPERATION.

NOTE # E7  
ELECTRICAL CONTRACTOR TO INSTALL TABLE LIMIT SWITCH TO END OF CLEAN DISHTABLE TO THAT MACHINE STOPS WHEN SWITCH IS DEPRESSED.

NOTE # E8  
ELECTRICAL CONTRACTOR TO CONNECT DRAIN LINE HEATER, PAN HEATER AND DODR HEATER FOR WALK-IN FREEZER.

## Equipment ELECTRICAL Service Requirements

All Dimensions to be verified on the job site. Actual locations for floor drains, and any ventilating equipment to be determined by Engineer. Mechanical, Plumbing & Electrical to be checked and verified by Customers MEP Engineer. Remote Condensing Units to be located by Architect. Exhaust & Supply fans to be located by Architect.

**Fish Pot - 4**  
**Kitchen**  
Portmore, Jamaica



2055 W 73rd Street, Miami, FL 33016  
Ph:(305)826-8696 Fax:(305)826-9131

No.	Revision/Issue	Date
6	Updated From Owner Comments.	11-15-18
7	Updated From Owner Comments.	11-19-18
8	Added MEP Sheets	11-28-18
9	Updated Background	1-31-19

Date  
**Jan 31, 2019**  
Drawn By  
**Dayne Gauntlett**  
Scale  
**3/8" = 1'0"**

Sheet  
**MK-3**